



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Craig W. Butler, Director

February 5, 2018

Certified Mail: 7017145000031527849

Sean Wallace
Ohio Mill Manger - P.H. Glatfelter Co.
232 East 8th Street
Chillicothe, Ohio 45601

**Re: P.H. Glatfelter Co. – Chillicothe Facility
Resolution of Violation (ROV)
Air Permit
Ross County
0671010028**

Division of Air Pollution Control

Subject: Resolution of Violation

Dear Mr. Wallace:

Thank you for your January 9, 2018 response to Ohio EPA's December 7, 2017 Notice of Violation (NOV) letter. Your response included documentation that a new computer for the data acquisition handling system for the package boilers (emissions unit B014 and B015) was ordered November 24, 2017, arrived January 4, 2018, and is being installed by P.H. Glatfelter Co. – Chillicothe Facility and VIM Technologies. Your response also included carbon monoxide (CO), nitrogen oxides (NOx) and oxygen (O2) emissions data as recorded by Glatfelter's operator control system from the mill's process data system for the package boilers.

Ohio EPA has reviewed the documentation that you provided and has determined that P.H. Glatfelter Co. – Chillicothe Facility has now resolved all the violations discovered during the April 1, 2016 inspection. To ensure that all the violations have been addressed, Ohio EPA has included P.H. Glatfelter Co. – Chillicothe Facility's response for each violation and its status.

Resolution of Violation

Letter Citation: Finding 1

Rule Citation: The terms and conditions of Title V permit-to-operate (PTO) P0090569, 40 CFR Part 60.48b(b) and Ohio Revised Code (ORC) 3745.05(C). The failure to continuously monitor and record CO emissions from emissions units B014 and B015.

The documentation that was submitted on January 9, 2018, included purchase records for a new computer for the data acquisition handling system for the package boilers (emissions unit B014 and B015) which was ordered November 24, 2017, and arrived January 4, 2018. Your response explained the new computer is being installed by P.H. Glatfelter Co. – Chillicothe Facility and VIM Technologies. Your response also included CO emissions data as recorded by Glatfelter's operator control system from the mill's process data system for the package boilers. Therefore, this violation is considered resolved.

Mr. Sean Wallace
P.H. Glatfelter Co. – Chillicothe
February 5, 2018
Page 2

Letter Citation: Finding 2

Rule Citation: The terms and conditions of Title V permit-to-operate (PTO) P0090569, 40 CFR Part 60.48b(b) and Ohio Revised Code (ORC) 3745.05(C). The failure to continuously monitor and record NOx and O2 emissions from emissions units B014 and B015.


The documentation that was submitted on January 9, 2018, included purchase records for a new computer for the data acquisition handling system for the package boilers (emissions unit B014 and B015) which was ordered November 24, 2017, and arrived January 4, 2018. Your response explained the new computer is being installed by P.H. Glatfelter Co. – Chillicothe Facility and VIM Technologies. Your response also included NO2 and O2 emissions data as recorded by Glatfelter's operator control system from the mill's process data system for the package boilers. Therefore, this violation is considered resolved.

Conclusion

Please note that this does not preclude the Director from seeking administrative or civil penalties pursuant to Ohio Revised Code section ORC Section 3704.06 for the violations noted in the December 7, 2018 NOV letter. The decision on whether to pursue or decline to pursue such penalties regarding these violations is dependent on several factors, one of which is the company's future compliance with Ohio EPA regulatory requirements.

Thank you for your time and cooperation and if you have any questions, please do not hesitate to contact me at (740) 380-5246 or by e-mail at racheal.davies@epa.ohio.gov.

Sincerely,



Racheal Davies
Environmental Specialist 2
Division of Air Pollution Control
Ohio EPA – Southeast District Office

RD/cs

cc: John Paulian/James Kavalec, DAPC/CO
Devan Roof, Supervisor, DAPC/SEDO
Brian Dickens, USEPA Region V